



City of Zilwaukee

319 Tittabawassee, Saginaw, MI 48604-1299
Phone (989) 755-0931 Fax (989) 755-2202

FROM THE ELECTRICAL INSPECTOR, CITY OF ZILWAUKEE

This is a list of some items in the past that have caused delays in hookup to a service or additional inspections that were required.

1. A permit must be obtained listing all electrical work that will be performed on the premise.
2. If a new service is required or alteration from the present location, a consumer request number is required. To obtain this, call 1-800-477-5050.
3. Fire caulk is required where electrical installations have entered the attic, basement or crawl space and all holes drilled adjacent to the garage wall.
4. On the permit, pay close attention as to who is required to obtain electrical plans with the proper signature and seal
5. Ground rods will be installed three to five feet on either side of new electrical service installation. Two ground rods installed per code will be needed if City water connection is not available.
6. If a piece of equipment that requires a large load such as central air conditioner is installed, a load calculation per code should be performed. If the equipment is installed and the service is found to be inadequate, the equipment will have to be removed from the electrical service.

Bruce Keidel

City of Zilwaukee Electrical Inspector

1/15/02

ElectricalBruceKeidel